

CERTIFICATE

NBN EN308 Heat Exchangers

for

heat recovery ventilation units:

Piccolo eco EC and Piccolo eco ECE

Normal air flow: 30 l/s, 108 m³/h

Supply fan power: 12 W

dT fan: 0,3 °C

t₂₁: 5,0 °C


t₂₂: 19,3 °C

t₁₁: 23,0 °C

$$\eta_t = \frac{t_{22} - t_{21}}{t_{11} - t_{21}} = 0,80$$

Heat exchangers thermal efficiency is 80 %

Porvoo 13.8.2010



Tom Palmgren

Technology Manager
Enervent Oy